

School Name	2020 Sample #	Sample Location	2020 First Draw Sample mg/L	2020 Flush Sample mg/L	2020 Pb ug/l	2020 Flush ug/l	Notes
Mamaroneck High School	20-3593-003	S-3L	0.133	0.0027	133	2.7	
	20-3593-010	S-7	0.0239	0.0356	23.9	35.6	
	20-3593-021	S-16	0.0866		86.6		Locked
	20-3593-024	S-19L	0.0866	0.009	86.6	9.01	
	20-3593-062	Steampot S-35	0.0413	ND	41.3	ND	
	20-3593-088	S-55	0.0828	0.0603	82.8	60.3	
	20-3593-091	S-58R	0.0381	ND	38.1	ND	
	20-3593-092	S-59L	0.0293	ND	29.3	ND	
	20-3593-104	Room 164 Left Sink	0.0386		38.6		
	20-3593-105	Facilities Kitchenette	0.0185		18.5		Locked
	20-3593-107	Business Office Conference Rm	0.214	ND	214	ND	
	20-3593-113	Custodian Office	0.019	ND	19	ND	
	20-3593-124	Room 168 M-Table L-Side R-Sink	0.0175		17.5		
	20-3593-138	Room 170 Storage Closet	0.0655		65.5		
	20-3593-140	Room 170 Teacher's Desk	0.018		18		
	20-3593-144	Room 170 R-Wall L-Sink	0.0798		79.8		
	20-3593-148	Room 170 Back Wall L-Sink	0.0343		34.3		
	20-3593-155	T28 Girls Bath Right Sink	0.0178	0.002	17.8	2.04	
	20-3593-156	Room 167 Teachers desk	0.0378		37.8		
	20-3593-158	Room 167 R-Table R-Side L-Sink	0.0368		36.8		
	20-3593-164	Room 167 R-Table L-Side L-Sink	0.053		53		
	20-3593-166	Room 167 M-Table R-Side L-Sink	0.0193		19.3		
	20-3593-170	Room 167 M-Table L-Side R-Sink	0.0189		18.9		
	20-3593-172	Room 167 M-Table L-Side L-Sink	0.0715		71.5		
	20-3593-174	Room 167 L-Table R-Side L-Sink	0.03		30		
	20-3593-176	Room 167 L-Table R-Side R-Sink	0.0312		31.2		
	20-3593-178	Room 167 L-Table L-Side R-Sink	0.0193		19.3		
	20-3593-187	Room 165 R-Table R-side L-Sink	0.0958		95.8		
	20-3593-189	Room 165 R-Table R-side R-Sink	0.0782		78.2		

20-3593-191	Room 165 R-Table L-Side L-Sink	0.0223	22.3
20-3593-193	Room 165 R-Table L-Side R-Sink	0.0438	43.8
20-3593-196	Room 263 L-Table R-Side R-Sink	0.0187	18.7
20-3593-201	Room 165 M-Table L-Side R-Sink	0.0338	33.8
20-3593-203	Room 165 L-Table R-side L-Sink	0.0246	24.6
20-3593-205	Room 165 L-Table R-side R-Sink	0.0487	48.7
20-3593-213	Room 163 R-Table R-Side L-Sink	0.0159	15.9
20-3593-218	Room 265 Mid-L-L Sink	0.0162	16.2
20-3593-232	Room 267 Front Sink	0.175	175
20-3593-233	Room 163 Storage Closet	0.282	282
20-3593-247	Room 366 Left Sink	0.0191	19.1
20-3593-248	Room 267 Mid-L-R Sink	0.0169	16.9
20-3593-249	Room 366 Storage Room	0.0874	87.4
20-3593-250	Room 267 L-R-L Sink	0.0173	17.3
20-3593-253	Room 370 Storage Room	3.96	3960
20-3593-254	Room 267 L-L-L Sink	0.0189	18.9
20-3593-255	Room 370 Teacher's Desk	0.0401	40.1
20-3593-259	Room 370 R-Wall L-Sink	0.0678	67.8
20-3593-261	Room 370 Back Wall R-Sink	0.138	138
20-3593-262	Room 270 Front Sink	0.0338	33.8
20-3593-265	Room 367 Teacher's Desk	0.0368	36.8
20-3593-266	Room 270 Back-Right Sink	0.0314	31.4
20-3593-269	Room 367 R-Table R-Side L-Sink	0.0818	81.8
20-3593-271	Room 367 R-Table R-Side R-Sink	0.0153	15.3
20-3593-272	Room 270 Lab Prep Sink	0.333	333
20-3593-273	Room 367 R-Table L-Side L-Sink	0.0346	34.6
20-3593-275	Room 367 R-Table L-Side R-Sink	0.0338	33.8
20-3593-277	Room 367 M-Table R-Side L-Sink	0.046	46
20-3593-281	Room 367 M-Table L-Side L-Sink	0.0782	78.2
20-3593-283	Room 367 M-Table L-Side R-Sink	0.0615	61.5
20-3593-285	Room 367 L-Table R-Side L-Sink	0.191	191
20-3593-287	Room 367 L-Table R-Side R-Sink	0.0917	91.7
20-3593-289	Room 367 L-Table L-Side L-Sink	0.0493	49.3
20-3593-291	Room 367 L-Table L-Side R-Sink	0.0228	22.8

	20-3593-293	Room 365 Storage Closet	0.177		177		
	20-3593-295	Room 365 Teachers Desk	0.0221		22.1		
	20-3593-303	Room 365 R-Table L-Side R-Sink	0.131		131		
	20-3593-315	Room 365 L-Table R-Side R-Sink	0.0196		19.6		
	20-3593-319	Room 365 L-Table L-Side R-Sink	0.0468		46.8		
	20-3593-326	C137 Right Left	0.0298	0.0013	29.8	1.29	
	20-3593-330	C137 Left Left	0.0301	0.0052	30.1	5.2	
	20-3593-332	C137 Left Middle	0.0267	0.0093	26.7	9.34	
	20-3593-345	Room 363 L-Table L-Side L-Sink	0.0191		19.1		
Mamaroneck Ave. School	2020 Sample #	Sample Location	2020 First Draw Sample mg/L	2020 Flush Sample mg/L	2020 Pb ug/l		Notes
	3593-043	S-11	0.0218	ND	21.8	ND	Right Sink Functional
	3593-086	001 Sink	0.0167	0.0053	16.7	5.3	
Hommocks	2020 Sample #	Sample Location	2020 First Draw Sample mg/L	2020 Flush Sample mg/L	2020 Pb ug/l		Notes
	3593-008	S-4	0.0961	0.0255	96.1	25.5	
	3593-015	S-10	0.0358	ND	35.8	ND	
	3593-025	S-12	0.0392	ND	39.2	ND	
	3593-028	S-15	0.0169	0.0012	16.9	1.21	
	3593-030	S-17	0.025	0.0013	25	1.27	
	3593-038	S307 - South Wall Left	0.0317		31.7		
	3593-039	S307 - South Wall Center	0.055		55		
	3593-040	S307 - South Wall Right	0.0417		41.7		
	3593-044	S308 - South Wall Far Left	0.0342		34.2		
	3593-050	S309 - South Wall Left	0.0151		15.1		
	3593-051	S309 - South Wall Center	0.0161		16.1		
	3593-054	2nd Floor South Wing Cust. Closet	0.0159	ND	15.9	ND	

	3593-056	S300 - West Wall Far Left	0.0176		17.6		
	3593-057	S300 - West Wall Left	0.0534		53.4		
	3593-059	S300 - North Wall Right	0.0169		16.9		
	3593-060	S301 - South Wall Left	0.135		135		
	3593-061	S301 - West Wall Far Left	0.0196		19.6		
	3593-063	S301 - West Wall Right	0.0828		82.8		
	3593-064	S301 - West Wall Far Right	0.218		218		
	3593-069	S302 - South Wall Center	0.0662		66.2		
	3593-077	S304 - North Wall Left	0.146		146		
	3593-079	S304 - North Wall Right	0.0334		33.4		
	3593-080	S304 - South Wall Left	0.086		86		
	3593-081	S304 - South Wall Center	0.215		215		
	3593-082	S304 - South Wall Right	0.108		108		
	3593-083	S305 - East Wall Far Left	0.126		126		
	3593-084	S305 - East Wall Left	0.181		181		
	3593-085	S305 - East Wall Right	0.154		154		
	3593-086	S305 - East Wall Far Right	0.0732		73.2		
	3593-087	S305 - South Wall Left	0.0477		47.7		
	3593-088	S305 - South Wall Right	0.0962		96.2		
	3593-091	S306 - East Wall Far Left	0.158		158		
	3593-093	S306 - East Wall Right	0.365		365		
	3593-094	S306 - East Wall Far Right	0.0927		92.7		
	3593-095	S211	0.0926	0.0046	92.6	4.62	
	3593-098	S206	0.075	ND	75	ND	
	3593-099	S205	0.0336		33.6		
	3593-100	S204	0.0262	0.0031	26.2	3.06	
	3593-104	S200	0.0247	0.0011	24.7	1.09	
	3593-107	N208	0.0158	0.0017	15.8	1.66	
	3593-108	N207	0.0345	0.0014	34.5	1.36	
	3593-109	N206	0.0268	0.0377	26.8	37.7	
	3593-110	N205	0.0563	0.0076	56.3	7.62	
	3593-112	N203	0.0171	0.0037	17.1	3.72	
	3593-113	N202	0.0459	0.0018	45.9	1.79	
	3593-114	N200	0.55	0.0021	550	2.14	

	3593-120	E203 Left Sink	0.0348		34.8		
	3593-121	E203 Middle Sink	0.0281		28.1		
	3593-135	S109 - South Wall Left Sink	0.0486		48.6		
	3593-136	S109 - South Wall Right Sink	0.0247		24.7		
	3593-139	S108 - South Wall Left Sink	0.0817		81.7		
	3593-140	S108 - South Wall Right Sink	0.06		60		
	3593-143	W100 - Left Sink	0.0843	0.0025	84.3	2.54	
	3593-149	Boys Locker Room Office Bath	0.0193	ND	19.3	ND	
	3593-152	W101 - Right Sink	0.0283	ND	28.3	ND	
	3593-153	Girls Locker - Center - Left Sink	0.0204	0.0019	20.4	1.93	
	3593-154	Girls Locker - Center - Right Sink	0.0205	0.0017	20.5	1.66	
	3593-158	Phys Ed Cust. Closet	0.0352	ND	35.2	ND	
	3593-161	Pool Men Locker Cust. Closet	0.0261	ND	26.1	ND	
	3593-171	S309 - North Wall Right	0.0229		22.9		
Central School	2020 Sample #	Sample Location	2020 First Draw Sample mg/L	2020 Flush Sample mg/L	2020 Pb ug/l		Notes
	3593-012	P-23 Bubbler	0.0152	ND	15.2	ND	
	3593-046	P-5	0.0279		27.9		Removed
	3593-054	P-44 Sink	0.0313	0.0042	31.3	4.2	
	3593-063	P-31 Sink	0.0254	0.0024	25.4	2.42	
	3593-080	P-16 Sink	0.0252	ND	25.2	ND	
	3593-092	CR 151 Left Sink	0.031	0.001	31	1.03	
Chatsworth	2020 Sample #	Sample Location	2020 First Draw Sample mg/L	2020 Flush Sample mg/L	2020 Pb ug/l		Notes
	3593-030	Office Sink	0.0267	ND	26.7	ND	
	3593-037	24 Sink	0.0201	ND	20.1	ND	

	3593-046	Strings Sink	0.145	0.0011	145	1.09	
	3593-047	Music Sink	0.0265	0.0013	26.5	1.29	
Murray	2020 Sample #	Sample Location	2020 First Draw Sample mg/L	2020 Flush Sample mg/L	2020 Pb ug/l		Notes
	3593-001	WC-1	0.0741		74.1		Not Working
	3593-003	S-2	0.048	0.0919	48	91.9	
	3593-021	Room 6 Sink	0.03	0.0013	30	1.34	
	3593-024	101 sink	0.0152	0.0016	15.2	1.61	
	3593-031	129 sink	0.0167	0.0175	16.7	17.5	